SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM


IREDELL
4862-49-1462

OWNER: CHRIS DILLOW APPLICANT: SAME
ADDRESS: P.O. Box 6883 STATESVILLE, NC APPLICATION DATE: 3-20-02 DATE EVALUATED: 04/10/
PROPOSED FACILITY: 3BR D/W MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.04 ACRES
LOCATION OF SITE: CHESHIRE RIDGE I, LOT #8 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L-5%	0-7	w, sbk, scL	VFr, ss, sP, sexP					0,3 PS
		7-23	m, sbk, sc	Fr, ss, sP, sexP					
		23-36	m, sbk, c	Fr, ss sP, sexP					
		36-48	m, sbk, sc	Fr, ss, sP, sexP	SAP mx				
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	IV
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Patrick Mitchell + Steve Hedrick
OTHER(S) PRESENT: CHRIS DILLOW


CARTWRIGHT ROAD