DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #:
COUNTY: IREDELL

4862 73 4261

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: RENEE DUCKWORTH APPLICANT: SAME
ADDRESS: 256 WATSIDE DR, STATESVILLE, NC APPLICATION DATE: 12-23-99 DATE EVALUATED: 1-12-99
PROPOSED FACILITY: 3BR DW/MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 6.76 ACRES
LOCATION OF SITE: CORNER OF ALLEN ROAD & WEST HOUSTONVILLE ROAD PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L	0-10	GR / SCL	VFR / NEXP					PS 0.25
		10-48	WFSBK / C	FR S/SP / NEXP					
2	L	0-12	GR / SCL	VFR / NEXP					PS 0.25
		12-48	WFSBK / C	FR S/SP / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: MS. DUCKWORTH & MOTHER