DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED:
COUNTY: IREDELL 17L-A-41 (PART)

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RANAH CHRISTIAN OWNER: ✓ AGENT: PHONE: 876-4974
ADDRESS: P.O BOX 134 APPLICATION DATE: DATE EVALUATED: 12-17-96
OLIN, NC 28660 PROPOSED FACILITY: 3BR D/W MH
PROPERTY SIZE: 17 ACRES +/-
LOCATION OF SITE: EAGLE MILL RD, TR HOUSTONVILLE RD, ON (R) PAST ALLEN ROAD
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	N 8%	0-42	SBK / C	1:1 / FI	—	—	PS	—	0.3
		42+	SAPROLITE	GR					
2	N 8%	0-42	SBK / C	1:1 / FI	/	/	PS	/	0.3
		42+	SAPROLITE	GR					
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MITNEY, CHRISTIAN, & CHRISTIAN
COMMENTS: KEEP SYSTEM NO DEEPER THAN 30"

0029005