HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 16K-A-53
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JONATHAN WAYNE CAMPBELL OWNER ✓ AGENT: PHONE: 539-9946
ADDRESS: RT. 2, BOX 93 APPLICATION DATE: 2/3/99 DATE EVALUATED: 2/3/99
HARMONY, NC 28634 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 11.75 AC
LOCATION OF SITE: I-77 N, EXIT NC 901, TR MILLS RD, ON (L) JUST BEFORE I-77 OVERPASS
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(2) MINEROLOGY		
1	L 8%	0-36	C	SBK	1:1/FR	.1942 WETNESS CONDITION	S
		36-48	C/SAP	GR/SBK	1:1/FR	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT²
2	N 8%	0-38	C	SBK	1:1/FR	.1942 WETNESS CONDITION	S
		38-48+	C	GR	1:1/FR	.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35 GPD/FT²
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JONATHAN CAMPBELL & FATHER
COMMENTS:

DRAFT