(I

704-913-2872
JEFF LOOPER

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134502 PIN# 4806-36-7562.22 DATE 3-29-06

OWNER OR APPLICANT Charles Holcomb PHONE: Business 828-466-2300 Home

ADDRESS 334 W Broad Hwy Statesville NC 28625

LOCATION 77N exit 65 (N) 901 (R) Eagle Mill Rd (R) TROY Mill 2nd on left

SUBDIVISION BLOCK / SECTION LOT LOT AREA 12 AC SITE CLASS. B DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 1017 Date 10-7-05
Pump Tank: Gallons: PT Date
Pump Make: Model Serial No.
Nitrification Field: No Fields Square Feet 1200 Linear Feet 300
No Lines 4 Trench Width 36 Max Trench Bottom Depth 36 Gravel Depth NA ☐ Gravity ☐ Pressure

☐ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI
System Description: 25% Graded
Repair System Description: 25% Graded
Maintenance Agreement Required: ☐ Yes ☐ No

☑ House/Mod. Home No. Bedrooms 3
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:
Well to Must 100' away from initial and Repair

Comments:/Conditions:
Maintain all setbacks
Install on contour

50
55
95
105

INITIAL SITE SKETCH

593

Stream

Repair 1000 g/o

Orig 1000 Gal Tk

Trench Repair

54.76 54.76 54.76 54.76

300

115

Stream

625

AS BUILT SKETCH

(Not to Scale) TUFFTITE Fitting & MARKER

MAINTAIN SETBACKS, SYSTEM INSTALLED BEFORE DECKED WELL was installed

Construction manager JEFF LOOPER CALLED & LEFT MESSAGE ABOUT DOG LOVE CHARLES Changes 704-913-2872

Dry Stream

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X date

Improvement Permit by: date 3-29-06

Authorization to Construct by: date 3-29-06

Installed by: A-1 BACKHOE

Operation Permit by: date 5-16-06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK