DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 16K-A-7
DATE: 6-21-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: CHASITTY N. YORK
ADDRESS: 288 UNION GROVE ROAD, UNION GROVE, NC 28689
OWNER ✓ AGENT: PHONE: 539-5233
APPLICATION DATE: 6/14/95 DATE EVALUATED 6/21/95
PROPOSED FACILITY: 2BR S/W MH
PROPERTY SIZE: 15 ACRES±
LOCATION OF SITE: I-77N, TL NC 901, TR UNION GROVE ROAD
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-4	SCL	GR	1:1 VFR			.1942 Wetness Cond. 5
	8%	4-40	C	SBK	1:1 FI			.1943 Depth/.1956 Sapr. 5
		40-48	SiC	wSBK	1:1 FR			.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3 GPD/FT²
2	H	0-2	SCL	GR	1:1 VFR			.1942 Wetness Cond. 5
	10%	4-36	C	SBK	1:1 FI			.1943 Depth/.1956 Sapr. 5
		36-48	SiC	wSBK	1:1 FR			.1944 Restrictive Hori. 5
								.1948 Profile Class. PS
								Profile LTAR 0.3 GPD/FT²
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS
SYSTEM TYPE CONVENTIONAL EQUITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: CHASITTY YORK
COMMENTS: