IREDELL COUNTY HEALTH DEPARTMENT

13643 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION 41588
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130, Article 13C)

OWNER OR CONTRACTOR CODY C. LYONS DATE 11/7/91 PERMIT NO. 12N-6-A-13

PHONE: Business _____ Home _____

LOCATION US 21 N, TL TOMLIN ROAD TL HICKORY GROVE ROAD, TR WINDMILL COURT, ON (L) LOT #13 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	PS
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.35 GPD/FTC
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6% LS
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	54"
			Rock or other impervious formations	NONE

Lot Area AMPLE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

ACP 9/23/91



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 11/7/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold