IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12916

OWNER OR CONTRACTOR ERNEST RUNGE DATE 6/6/91 PERMIT NO. 12N6-A-2

PHONE: Business _____ Home _____

LOCATION US 21 N, TL TOMLIN RD, TL HICKORY GROVE RD, TR DUTCHMAN CREEK EST, 1ST LOT ON (R) S. R. No. _____

SUBDIVISION NAME DUTCHMAN CREEK EST LOT NO. 2 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil PS
Percolation Rate 4 GPD / FT 2
4-6 PD 20 LS
Topography _____
Depth to Water Table > 4'
Rock or other impervious formations NONE

Lot Area _____

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

ACP 5/1/91

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 6/6/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold