DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: 4870106659
COUNTY: PRINCE GEORGES

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: GERETHA WASHINGTON APPLICANT: JOHN & WILMA SPEECE
ADDRESS: 6806 NASHVILLE RD, LANHAM, MD 20706 APPLICATION DATE: _____ DATE EVALUATED: 10-22-98
PROPOSED FACILITY: SBR DW MH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 1.5 ACRES
LOCATION OF SITE: US 2 N, TL GALLIHER RD, 7TH HOUSE ON LEFT PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 6%	0-48	SBK / C-CL	FR-FI / NEXP					PS 0.3
2	L 6%	0-48	SBK / C-CL	FR FI / NEXP					PS 0.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HOSBACK
OTHER(S) PRESENT: _____