IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Morrison Windsor DATE 6/29/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21N – Go past Log Cabin Service Station, go ½ mile, mobile home on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Clay
Percolation Rate none
Topography 2-6% slope
Depth to Water Table 6ft
Rock or other impervious formations none observed

Lot Area _____



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 750
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public (✓)

Installed by Eddie Young

IMPROVEMENTS PERMIT BY _____

COMMENTS: System originally designed for 2 mobile homes – only one will be using system – standard system for single dwelling installed

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 6/29/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold