IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OR CONTRACTOR Iredell Co. EMS DATE 12-2-88 PERMIT NO. AR

Home

ON Intersection of 21N & Little Willowbrook Rd in Harmony

S. R. No.

VISION NAME LOT NO. SECTION OR BLOCK NO.


Mobile Home ( ) Business ( ) Other

rooms 2 No. Bathrooms 3

Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil prev suitable
ishwasher	Yes ( )	No (✓)	Percolation Rate 4
Wash. Machine	Yes ( )	No (✓)	Topography 2to4%
Table	Yes (✓)	No ( )	Depth to Water Table 10+
			Rock or other impervious formations none

Ample

Basement with Plumbing ____ Basement ~~without Plumbing~~ ____ No Basement



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 500 Linear Ft. 330
Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public (✓)

Installed by Sammy Reid's

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

OVEMENTS PERMIT BY Okeover & Vera Fay

IENTS:

TIFICATE OF COMPLETION BY Okeover DATE 12 2 88

SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making ...ements Permit.

Health Dept. Copy; White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold