DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Willie Kennedy
ADDRESS: 541 Crawford Rd. Harrisburg
PROPOSED FACILITY: 3 BR residence PROPOSED DESIGN FLOW (.1949): 360 gpd
LOCATION OF SITE: Hwy 21N TR 901 TR Crawford .3 mile on RT.
WATER SUPPLY: • Private • Public • Well • Spring • Other _____
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 12/6/09
DATE EVALUATED: 12/6/09
PROPERTY SIZE: _____
PROPERTY RECORDED: _____
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 12%	0-14	SBK/C	Fr/SPL/P	>18	>18	—	—	PS 0.3
		14-18+	wSBK/C1	Fr/SPL					
2	L 12%	0-12	SBK/C	Fr/SPL	>18	>18	—	—	PS 0.3
		12-18+	wSBK/C1	Fr/SPL					
3	L 12%	0-14	SBK/C	Fr-SPL	>18	>18	-	-	PS 0.3
		14-18+	wSBK/C1	Fr/SPL					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	I 25%	I 25%
Site LTAR	0.7	0.7

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: JCH
OTHER(S) PRESENT: _____

75' from Road / 25' from Intermittent

COMMENTS: _____