IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Raymond Myers DATE 25 Aug 75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N to Harmony. T.R. on Highland Ave. Trailer behind third house on left

SUBDIVISION NAME _____ S. R. No. _____


LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	40
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	48
			Rock or other impervious formations	rock

Lot Area _____



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wm Howard DATE 25 Aug 75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold