DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 12N-A-102 (PART OF)
DATE: 9-25-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: KENT GREEN
ADDRESS: 148 HAYES ST.
HARMONY, NC 28634

OWNER ✓ AGENT: PHONE: 546-7583
APPLICATION DATE: 9-18-95 DATE EVALUATED 9-25-95
PROPOSED FACILITY: 3BR S/W MH
PROPERTY SIZE: 145 x 225±86

LOCATION OF SITE: SAGEFIELD I, LOT #3
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	H	0-36	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. S
	6%	36-48	SILTY	SAPROLITE				.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.25 GPD
2	H	0-36	C	WFSBK	1:1/FI/SS/SP			.1942 Wetness Cond. S
	7%	36-48	SILTY	SAPROLITE				.1943 Depth/.1956 Sapr. PS
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.25 GPD
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.25 GPD/FT²

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: PREACHER GAITHER, KENT GREEN

COMMENTS: