DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 4870838723
COUNTY: Leon

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tracey Rodgers
ADDRESS: 423 Stimson St. Orlando Florida
PROPOSED FACILITY: 3BR Repair
LOCATION OF SITE: 170 Redman Rd.
WATER SUPPLY: • Private • Public • Well • Spring • Other N/A
EVALUATION METHOD: • Auger Boring • Pit • Cut

APPLICATION DATE 5-6-13
DATE EVALUATED: 5-17-13
PROPERTY SIZE: 1.02
PROPERTY RECORDED: YES
TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROPOSED DESIGN FLOW (.1949): 360 gpd

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	9% HS	0-23	C SBK	Fi Mod SE	+48"	45"	45"	45"	PS 0.3
		23-45	CL MOD WSBK	Fr Mod SE					
		45-48	SAP						
2	12% HS	0-25	C SBK	Fi Mod SE	+48"	+48"	+48"	+48"	PS 0.3
		25-48	CL MOD WSBK	Fi Mod SE					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		PS
System Type(s)		II
Site LTAR		0.3

OTHER FACTORS (.1946): N/A
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Justin Henderson
OTHER(S) PRESENT: N/A

COMMENTS: N/A