EPARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 4871 22 1323
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: William & Stacy QUEEN OWNER: / AGENT: PHONE: 873 2021
DDRESS: 365 Little Wilkesboro Road APPLICATION DATE: 4-29-98 DATE EVALUATED: 5-26-98
Harmony, NC 28634 PROPOSED FACILITY: 3BR SD/W MH
PROPERTY SIZE: AMPLE
CATION OF SITE: US 21 N, TL NC 901, TR Little Wilkesboro Rd.
ATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	H 6-8%	0-11	WMSBK / CL	1:1 / FR	-	-	PS	PS	0.33
		11-32	MMSBK / SiCL	1:1 / FR					
		32-48	WMSBK / SiL	1:1 / VFR					
2	H 6-8%	0-10	WMSBK / CL	1:1 / FR	-	-	PS	PS	0.33
		10-30	MMSBK / SiCL	1:1 / FR					
		30-48	WMSBK / SiL	1:1 / VFR					
3									
4									
5									

AILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT
VALUATED BY: S. NEDRICK OTHER(S) PRESENT: WILLIAM QUEEN
OMMENTS: SUBSURFACE INTERCEPT DRAINAGE DITCH REQUIRED

0013195