IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 080824 PIN# 4871 43 7663 DATE 8-10-99

OWNER OR CONTRACTOR ANGELA MARLOWE PHONE: Business Home 546-5252

ADDRESS 192 RABBIT HWY HARMONY NC 28634

LOCATION US 21 N, TL LITTLE WILKESBORO RD, TR RABBIT HWY, 2ND DRIVE ON RIGHT

SUBDIVISION BLOCK / SECTION LOT LOT AREA 1.54 ACRES SITE CLASS PTS DESIGN FLOW 360 L.T.A.R. 0.30 GPD/FT²

BARN

Septic Tank: 1000 Gallons; STB 1012 Date 6-14-99

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines THREE Trench Width 36" Max Trench Bottom Depth 30"

☑ New System ☐ Repair System Type: I II III IV V VI

System Description: CONVENTIONAL GRAVITY

Repair System Description: CONV. GRAVITY

Maintenance Agreement Required: ☐ Yes ☑ No

Gravel Depth 12" ☐ Slab ☐ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing

☐ House/Mod. Home No. Bedrooms 3

☐ Mobile Home No. Bathrooms 2½

☐ Business No. Employees

☐ Other

Water Supply: ☑ Individual ☐ Public ☐ Community WELL

Comments/Conditions: SEE ATTACHED EASEMENT

SHED

INITIAL SITE SKETCH

POPLAR TREES

3' x 134'

3' x 133'

EXISTING DRIVE

39'

15'

5'

PROPOSED HOUSE

REPAIR AREA

PROPERTY LINE

SEPTIC TANK

DROP BOXES (3)

POPLAR TREE

Comments/Conditions

EXISTING HOUSE

64'

AS BUILT SKETCH

Installed as shown

PROPOSED DRIVE

PROPERTY LINE

28'

PROPERTY LINE

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Angela Carter-Marlowe date 8-13-99

Improvement Permit by: STEVE HEDRICK date 8-10-99

Authorization to Construct by: STEVE HEDRICK date 8-10-99

Installed by:

Operation Permit by: Kenny Madison Mark C. Oates date 8-18-99

Existing System Inspection by: date

RABBIT HIGHWAY (SR 1837)

HEALTH DEPT COPY WHITE OWNER COPY (FINAL) YELLOW OWNER COPY (INITIAL) PINK