IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

REPAIR
OWNER OR CONTRACTOR PEARL WAMPLER PROPERTY DATE 3/25/91 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION US 21N, TL LITTLE WILKESBORO ROAD, ON (R) PAST HARMONY EMS S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil _____
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations EXISTING

Lot Area AMPLE

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank EXISTING Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 180 Linear Ft. ~30FT
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (✓)

Installed by A-1 BACKHOE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEDRICK

COMMENTS: TANK WAS PUMPED OUT, NEW LID INSTALLED, NEW 'T' INSTALLED; 6'x30' BED SYSTEM INSTALLED ON CONTOUR & TIED INTO EXISTING LINE; EARTHEN DAM CONSTRUCTED AT PROPERTY LINE, ~30' ABANDONED; WASHER DRAIN TIED INTO SYSTEM.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 3/25/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold