DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 17F-A-37
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

J.C. SMITH
APPLICANT: JACK JONES OWNER / AGENT: PHONE: 546-7494
ADDRESS: RT. 2 BOX 145-A APPLICATION DATE: 6/28/93 DATE EVALUATED: 6/28/93
HARMONY, NC 28634 PROPOSED FACILITY: 3BR S/W MH
PROPERTY SIZE: ACREAGE
LOCATION OF SITE: US 21 N TL MAYBERRY ROAD, 3RD DWELLING ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 6-8%	0-24	ABK / L	1:1 / VFI	S	S	PS	N/A	0.3
		24-48	WSBK / C	1:1 / FI	S	S	PS		0.35
2	N 6-8%	0-28	ABK / C	1:1 / VFI	S	S	PS	N/A	0.3
		28-48	WSBK / C	1:1 / FI	S	S	PS		0.35
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.356GPD/FT
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: JACK JONES
COMMENTS: