IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

REPAIR

OWNER OR CONTRACTOR RONNIE JONES DATE 5/13/92 PERMIT NO. REPAIR

PHONE: Business _____ Home _____

LOCATION US 21N, TL MAYBERRY ROAD, 1ST HOUSE ON (R)

SUBDIVISION NAME _____ S.R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area AMPLE

Soil Characteristics _____


Application Rate _____

Topography _____

Depth to Water Table EXISTING

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank EXISTING Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 450 Linear Ft. 150

Depth of Stone in Lines 12"

Water Supply: Individual ☑ WELL

Public ☐

Installed by TOMMY FRYE

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS (1) TANK PUMPED OUT 5/13/92.
(2) NEW SANITARY TEE INSTALLED.
(3) TANK IS BUILT IN PLACE W/ DIRT FLOOR.

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 5/13/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold