IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

10363 (Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Waco Hefner DATE 9/87 PERMIT NO. 175-A-87

PHONE: Business _____ Home _____

LOCATION 2118 E Powell Bridge Rd on Bethesa Friendship Church

SUBDIVISION NAME _____ LOT NO. _____ S. R. No. _____

House ( ) Mobile Home (X) Business ( ) Other _____ SECTION OR BLOCK NO. _____

Ike Mcintyre

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 2.45 AC

Character & Porosity of Soil Fair Suitable


Percolation Rate _____

Topography Rolling

Depth to Water Table 10'

Rock or other impervious formations None

_____ Basement with Plumbing ___/___ Basement without Plumbing _____ No Basement



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Lineal Ft. 200

Depth of Stone in Lines 12

Water Supply: Individual ( )

Public (X)

Installed by James V Allen

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

Plot of System

IMPROVEMENTS PERMIT BY Williams

COMMENTS: Use Lineal bottom Mead Tank

CERTIFICATE OF COMPLETION BY Williams

EXISTING SYSTEM CHECKED BY: _____ DATE 9/87

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold