DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ANDY ALLEN APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 1/26/01
PROPOSED FACILITY: 3 BR PROPOSED DESIGN FLOW (.1949): 360 GPD PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1		0-3	SL VWSBK	VFr NSNP	≥ 48"	≥ 48"	N/A	N/A	PS .3
		3-14	SL WSBK	Fr SS SP					
		14-40	C MSBK	Fi-Fr SP					
		40-48	C/SAP W MSBK	Fr SS SP					
2		0-15	SL VWSBK	VFr NSNP	≥ 48" Y/B 40+	≥ 48"	N/A	N/A	PS .35
		15-22	SCL WSBK	Fr SS SP					
		22-48	SL WSBK	Fr SS SP					
3		0-6	SL		≥ 15" Y/B ≥ 22" CHROMA 2				U
		6-10	SCL						
		10-22	SC						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___