EPARTMENT OF ENVIRONMENT, HEALTH AND [illegible]
IVISION OF ENVIRONMENTAL HEALTH
N-SITE WASTEWATER SECTION

PROPERTY ID #: 4872067994
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

)WNER: Bob Fromme APPLICANT: SAME
\DDRESS: 204 CORNWALL ROAD Mooresville APPLICATION DATE: _____ DATE EVALUATED: 5-29-98
'ROPOSED FACILITY: 3BR House PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: _____
.OCATION OF SITE: 151 YORK SPANN ROAD PROPERTY RECORDED: _____
VATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
:VALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
:YPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

P. R O F I L E #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 4%	0-7	GR / GRSL	FR / 1:1	—	—	PS	—	0.4 PS
		7-11	WMSBK / CL	FR / 1:1					
		11-32	MMSBK / C	FI / 1:1					
		32-48	SBK-MMS/CL-SNP	FR / 1:1					
2	H 4%	0-6	GR / GRSL	FR / 1:1	—	—	PS	—	0.4 PS
		6-10	WMSBK / CL	FR / 1:1					
		10-30	MMSBK / C	FI / 1:1					
		30-48	WSBK / CL-SNP	FR / 1:1					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	CONV GRAVITY	CONV GRAVITY
Site LTAR	0.4	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S HEDRICK
OTHER(S) PRESENT: Bob Fromme