ICHD - ENVIRONMENTAL HEALTH DIVISION

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # AP-318874

SEPTIC: IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4872 -- 27 -- 9911

APPLICANT/OWNER: MICHELLE STEVENSON APPLICANT ADDRESS: 363 TROY MILL ROAD, HAMPTONVILLE, N.C. 27020

SITE ADDRESS: 342 TROY MILL ROAD, HAMPTONVILLE, N.C. 27020 PHONE: 704-273-6391 ALT. PHONE –


SITE DIRECTIONS: (N) ON 77, (R) ON 901, (L) ON EAGLE MILL, (R) ON WEST HOUSTONVILLE, (L) ON TROY MILL, LOT ON (R) SAP CONTROLLED: ☑ YES ☐ NO

SUBDIVISION: – SECTION: – LOT # – LOT AREA: 1.543 AC DESIGN FLOW: 240 GPD L.T.A.R.: 0.25

Septic Tank	1000	(gal)	STB	851	Date	11/24/22	☑ New System	☐ Repair	☐ Expansion	System Type: I II III IV V VI	☑ Residence	No. Bedrooms	2	Water Supply	
Pump Tank	–	(gal)	PT	–	Date	–	System Description:			25% REDUCTION	☐ Business	No. Persons	4	☑ Private	EXT
Pump Make	–	Model		–	Serial #	–	Repair System Description:			25% REDUCTION	☐ Other	No. Employees	–	☐ Public	
# Nitrification Fields	1	# Lines		2	Linear Ft	240ft	Maintenance Agreement Required:		☐ YES	☑ NO	☐ Slab	☑ Crawl Space		☐ Community	
Trench Width	36 IN	Trench Bottom Depth(Low side)		28 IN	Gravel Depth	–	☑ GRAVITY		☐ PRESSURE		☐ Basement w/plumbing			☐ Basement w/o plumbing	

Comments / Conditions: INSTALL ON CONTOUR, INSTALL ON 9ft CENTERS, UTILIZE SERIAL DISTRIBUTION, MAINTAIN 100ft FROM ALL WELLS, DO NOT EXCEED A 36IN MAX TRENCH DEPTH, HOUSE MUST BE 25-FT FROM WELL


INITIAL SITE SKETCH



AS BUILT SKETCH

FOR SEPTIC FINAL INSPECTION CALL: 704-664-3703 between 8am-9am the day the inspection is needed. Be sure to speak with an inspector to confirm your time.

1 IN = 50 FT
S.T. = SEPTIC TANK
EXT = EXISTING



Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☐ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Michelle Stevenson Date: 12/1/21 Installed by: A1 Backhoe


IMPROVEMENT PERMIT by: Bryant C. White Date: 11-29-2021 OPERATION PERMIT by: Cory Hill Date: 3/20/23

AUTHORIZATION TO CONSTRUCT by: Bryant C. White Date: 11-29-2021 Existing System Inspected by: Date:

FOR SEPTIC FINAL INSPECTION: CALL 704-664-3703 between 8am-9am the day the inspection is needed.


Item	Date	Initials
Drain Lines Checked		
Tanks Checked		
Pressure Manifold or Valve Box Checked		
Pressure Head Set		
Electrical Checked		
Floats Set		
Alarm Checked		
Maintenance Contract Needed? Y / N		
Comments:		

Repairs Only	
	State Code
Failing System Code	
Type of Distribution	G or P
Type of Failure/Malfunction	
Primary Cause of Failure/Malfunction	
Age of System? _____	
Initial or Repair? _____	


10
334
4872-28-8238
2
946
100
348
4872-28-8049
165
79
4872-49-03
342
3
334
342
Troy Mill Rd
4872-27-4929
170
PIT2
4872-27-9911
PIT3
201
PIT1
100
4872-27-4859
226
PIT 4
103
249
103
124
4872-27-8734
4872-37-0741
151
366
231

Floor Plan

342 Troy Mill



Acknowledgement Of
Plans Submittal ONLY!

Date 12/1/21

Date 11-29-2021

DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 1
PROPERTY ID #: 4872-22-9911
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: MICHELLE STEVENSON — APPLICATION DATE 6-17-2021
ADDRESS: 363 TROY MILL ROAD, HAMPTONVILLE, N.C. 27020 — DATE EVALUATED: 10-27-2021
PROPOSED FACILITY: 2BR — PROPOSED DESIGN FLOW (.1949): 240 GPD — PROPERTY SIZE: 1,543 AC
LOCATION OF SITE: 342 TROY MILL ROAD, HAMPTONVILLE, N.C. 27020 — PROPERTY RECORDED: YES
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut — TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	LINEAR SIDE 12%	0-17	SBK	FI, S, P, SEXP	SAP INC THRU OUT	36"	PS II L	N/A	PS .3
		17-36	CL, WSBK	FR, SS, SP, SEXP					
		36-63	SAP, MAS	VFR, NS, NP, SEXP					
2	LINEAR SIDE 10%	0-5	FILL	MIXED	Y/B MOTS ALONG ROOT CHANNELS SAP INC THRU OUT	48"+	N A	N A	PS .25
		5-32	C, ABK	FI, S, P, SEXP					
		32-48	CL WSBK	FR, SS, SP, SEXP					
3	LINEAR SIDE 17%	0-15	C, ABK	FI, S, P, SEXP	FEW Y/B MOTS 0-18" ROCK VIEN @ 35" NON-CON SAP INC THRU OUT	36"	PS II L	N A	PS .275
		15-36	CL, WABK	FR, SS, SP, SEXP					
		36-59	SAP, MAS	VFR, NS, NP, SEXP					
4	LINEAR SIDE 15%	0-48	C, ABK	FI, S, P, SEXP	FEW Y/B MOTS THRU OUT SAP INC THRU OUT	48"+	N A	N/A	PS .275

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	25%	25%
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Bryant C. White
OTHER(S) PRESENT:

COMMENTS:

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope) CV (Convex Slope) D (Drainage Way) DS (Debris Slump) FP (Flood Plain) FS (Foot Slope) H (Head Slope) L (Linear Slope) N (Nose Slope) R (Ridge) S (Shoulder Slope) T (Terrace)	I	S (Sand) LS (Loamy Sand)	1.2 - 0.8	0.6 - 0.4	SEXP (Slightly Expansive) EXP (Expansive)	G (Single Grain) M (Massive) CR (Crumb) GR (Granular) SBK (Subangular Blocky) ABK (Angular Blocky) PL (Platy) PR (Prismatic)
	II	SL (Sandy Loam) L (Loam)	0.8 - 0.6	0.4 - 0.3		
	III	Si (Silt) SiCL (Silty Clay Loam) CL (Clay Loam) SCL (Sandy Clay Loam) SiL (Silt Loam)	0.6 - 0.3	0.3 - 0.15		
	IV	SC (Sandy Clay) SiC (Silty Clay) C (Clay)	0.4 - 0.1	0.2 - 0.05		
		O (Organic)	None	None		

MOIST	WET
VFR (Very Friable)	NS (Non-sticky)
FR (Friable)	SS (Slightly Sticky)
FI (Firm)	S (Sticky)
VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
EFI (Extremely Firm)	NP (Non-plastic)
	SP (Slightly Plastic)
	P (Plastic)
	VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.


NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).



Updated February 2014

RECEIVED JUN 17 2021

APPLICATION MUST BE FILLED OUT COMPLETELY & BE LEGIBLE
OR IT WILL NOT BE PROCESSED

Iredell County Health Department – Environmental Health Division

PAGE 1: *APPLICATION FORM* AP-318874 $250.00

Application For: ( ) New Well Permit ( ) Well Repair Permit ( ) Well Abandonment
( ) Septic Improvement Permit ( ) Authorization to Construct (✓) Existing System Inspection ( ) Septic System Repair

THE ABOVE PERMIT DOCUMENTS WILL BECOME INVALID IF INFORMATION PROVIDED ON THIS APPLICATION IS FALSIFIED OR CHANGED, OR IF THE SITE IS ALTERED. THE IMPROVEMENT PERMIT IS VALID FOR EITHER 60 MONTHS OR WITHOUT EXPIRATION DEPENDING UPON DOCUMENTATION SUBMITTED. APPLICATION WITH SITE PLAN 60 MONTHS. APPLICATION WITH COMPLETE, SCALED PLAT WITHOUT EXPIRATION. SEE 15A NCAC 18A .1937(f) FOR DETAILS.

Page 2: *Site Plan Worksheet* form MUST accompany this application

The following optional attachments may also be submitted: ( ) Survey Plat, scaled no more than 1 inch = 60 feet
Place an (X) beside whichever is submitted if applicable ( ) Custom Site Plan, scaled no more than 1 inch = 60 feet

Applicant Information: (PRINT CLEARLY)

Applicant Name: Michelle Stevenson Address: 342 Tray Mill Rd Hamptonville NC Zip: 27020

Applicant Email: _____ Phone: _____ Alt. Phone: _____

Owner Name: _____ Address: _____ Zip: _____

Owner Email: _____ Phone: _____ Alt. Phone: _____

Property Information:

Street Address: 342 Tray Mill Rd Hamptonville NC 27020

Subdivision Name: _____ Section/Phase: _____ Lot Number: _____

Driving Directions: HWY 901 - Eagle Mills - ® Houstonville - (L) Tray Mill - 1mile on Right

Site Development Information: *(check or complete ALL that apply*

(✓) New Single Family Residence
( ) New Multi-Family Residence
( ) Accessory Building
( ) Bedroom(s) Addition
( ) Repair to failing septic system ___ Tank ___ Drain lines Describe Problem: _____

Maximum Number of Bedrooms: 2
Maximum Number of Occupants: 3
( ) Swimming Pool
( ) Other Addition/Structure: _____

CHECK FOUNDATION TYPE
(✓) Crawl Space Foundation
( ) Concrete Slab Foundation
( ) Basement with Plumbing
( ) Basement without Plumbing

Non-Residential Site Development: Type of Business: _____
Square Footage of Building: _____ Max. Number of Employees: ____ Max. Number of Seats/Beds/Other: ____

Water Supply: ( ) Replacement Well – Reason: _____
( ) Multi-connection Well Number of Houses: _____ Number of Persons: _____

( ) New Well (✓) Existing Well ( ) Community Well ( ) City Water ( ) Other Public Water

Desired Septic System Type: *(you may rank in order of preference)* Year existing system installed: ?
( ) No Preference ( ) Alternative (✓) Conventional ( ) Innovative ( ) Modified Conventional ( ) Other: _____

Please answer the following to the best of your ability:

( ) Yes (✓) No Does the site contain any jurisdictional wetlands?
( ) Yes (✓) No Is any non-domestic sewage (i.e. industrial) to be generated?
( ) Yes (✓) No Is the site subject to approval by any other public agency?

I have read this application and certify that the information provided herein is true, complete, and correct. Authorized county and state officials are granted right of entry to conduct necessary inspections to determine compliance with applicable laws and rules. I understand that I am solely responsible for the proper identification and labeling of all property lines and corners and making the site accessible so that a complete site evaluation can be performed.


Signature: _____ 6/16/21
Property owner or owner's legal representative signature (SIGNATURE REQUIRED) DATE

IREDELL COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

PAGE 2: *SITE PLAN WORKSHEET*

SEE THE "SAMPLE SITE PLAN" BELOW. ***INCOMPLETE SITE PLANS WILL BE RETURNED TO YOU FOR COMPLETION AND MAY RESULT IN A DELAY IN THE ISSUANCE OF YOUR SEPTIC SYSTEM PERMIT!!!***



Place an (X) beside each item as you complete the site plan:


( ) Property Line measurements are clearly identified
( ) All proposed structures are indicated
( ) Front and side setbacks from property line
( ) Preferred driveway location and well location
( ) Area you prefer your septic system to be placed
( ) North arrow, or other sufficient indicator of direction

Circle N/A on the following if appropriate:

Location of septic systems and wells within 100' of your property	N/A
Location of easements and rights of ways on your property	N/A
Location of any designated wetlands on the property	N/A

USE THIS SPACE TO DRAW YOUR SITE PLAN

Show: proposed house or business footprint, wells, water lines, patios, pools and decks, and any other item that will occupy space on the site



Signature: Michelle Arenas

Property owner or owner's legal representative signature (SIGNATURE REQUIRED)

6/16/21

DATE

IREDELL COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

DOCUMENTATION TO AUTHORIZE AN OWNER'S LEGAL REPRESENTATIVE

(Check and sign only ONE of the options below)

✓ 1. * APPLICANT AND OWNER ARE THE SAME. * *(Sign here)* Michelle D Stevenson

Applications for permits require the "signature of the owner or owner's legal representative" (15A NCAC 18A .1937). If the owner does not sign the application himself or herself, they can submit any one of the following documents to designate their legal representative: *Power of Attorney; Real Estate Contract; Estate executor; Bankruptcy trustee; Court ordered guardianship* In the absence of the above documentation, the property owner may provide the local health department with documentation that designates a legal representative. A property owner may:
Complete this form to document his or her legal representative, or provide his or her own form that contains the information in this form. If there are multiple property owners, then all property owners must sign the form that designates a legal representative.
By signing a form that designates a legal representative for purposes of 15A NCAC 18A .1937, the property owner authorizes that representative to act on their behalf in matters pertaining to the application and permitting process, including signing or receiving any application, document or permit. The owner retains full responsibility to meet all permit conditions specified by the local health department.

2. I, Michelle Stevenson, am the legal owner(s) of the property located at 342 Troy Mill Rd Hamptonville NC 27020, identified as PIN (Parcel Identification Number) 4872279911.0000, located in Iredell County, North Carolina.

I do hereby authorize (print legal representative/company name) Michelle Stevenson, to act as an agent on my behalf in applying for/signing/obtaining any of the documents described below.

- Application for Improvement Permit (IP) / Authorization to Construct (AC)
- Improvement Permit (IP) / Authorization to Construct (AC)
- Application for soil-site evaluation (new/repair)
- Application/permit for private drinking water well/well abandonment
- Application for Compliance Inspection

I agree to abide by all decisions and/or conditions between the legal representative acting on my behalf and the Iredell County Department of Public Health, Environmental Health Division.

Michelle D Stevenson — Signature of Owner(s)

6/16/21 — Date

Mooresville - Environmental Health
Fax: 704-662-3239
610 E. Center Avenue, Mooresville, NC 28115

Statesville - Environmental Health
ronda.hart@co.iredell.nc.us
Fax: 704-871-3483
349 N. Center Street, Statesville, NC 28677

ENVIRONMENTAL HEALTH REQUIREMENTS for SEPTIC and WELL PERMITS

The following items must be completed *PRIOR* to the *SUBMITTAL* of any Environmental Health Application. Incomplete applications will be returned to the applicant and cannot be processed or placed on the work list

***Initial all lines below to indicate you have submitted each form and completed every site requirement ***

MS ✓ **Complete all Environmental Health forms:**

✓ Application

✓ Site Plan including the dimensions of proposed structure, addition, pool etc.

✓ Documentation to Authorize Owner Agent (even if the property owner is the applicant – complete section 1 or 2)

✓ Copy of Zoning Permit when applicable

✓ Sign this sheet after you have completed all items

MS Lot must be cleared of heavy undergrowth. In order to evaluate the lot, the footprint of the proposed structure must be visible. Adequate area for the septic drain field and repair area must be sufficiently cleared of heavy undergrowth, with 50 feet of visibility in all directions. Inspectors must be able to evaluate the property, shoot laser level elevations, layout the drain field, do soils work, etc. If the lot is not cleared sufficiently, then a $100 site revisit fee will be charged and the evaluation will be put on HOLD until the requirement is met.

MS Clearly mark all property corners by locating existing iron or concrete markers. Flag all property lines every 25 feet if adjacent corners are not visible when standing on any given corner. Property lines must be flagged by a licensed NC surveyor & easily identified **prior to application submittal** (exception may apply for septic repair evaluations only).
'Mow lines' and/or fence lines do NOT constitute marked lines. **If the property lines are not properly marked when the lot is ready to be evaluated, then the application will be put on HOLD and a $100 site re-visit fee charged.**

MS Stake or flag the footprint of the proposed structure, addition, pool etc. to match the site plan submitted. The proposed structure, etc. must be staked out on the property as per the site plan.

MS If an Authorization to Construct (AC) is desired, submit a recorded copy of the plat for newly created or subdivided lot(s) and a LEGIBLE copy of the basic floor plan no larger than 8 ½" x 14" for each floor of the structure including decks, porches, etc. **The overall dimensions must be clearly noted & the rooms labeled.**

Any site not meeting the above requirements when staff arrives for the evaluation will result in a $100 site revisit fee being charged and the request being placed on HOLD. This will delay the processing of the application. *Once work by Environmental Health staff begins, the up-front fees paid toward securing any health department permit are nonrefundable. Refunds for work not started, due to a customer changing their mind or plans, are subject to an administrative fee of $50 to defray a portion of the costs of processing the refund.*

Backhoe pits are required for all applications that require a soils evaluation.
DO NOT DIG PITS UNTIL THE EH SPECIALIST HAS AUTHORIZED AND SCHEDULED YOUR EVALUATION TIME.

- All utilities shall be marked before pits are dug. Call NC 811 for this service.
- The applicant/agent is responsible for securing these services
- Backhoe pits are to be dug at the locations and depths determined by the Environmental Health Specialist or a NC Licensed Soil Scientist. A minimum of four pits must be dug.
- The EH specialist will contact you when your application is ready to be processed for pit scheduling.
- Your backhoe operator must be on site during the EH Specialist's evaluation to prevent your operator from having to return to the property for additional work.

By signing below I am acknowledging the above specifications have been met and the site is READY to be evaluated AND I understand the backhoe pit requirement and will secure those services (if applicable).

Signature Michelle Stevenson Date 6/16/21

Questions? Contact the Environmental Health Offices below:

Statesville Office
349 North Center Street (2nd Floor Building Standards)
Statesville, NC 28677-4063
Phone: (704)878-5305 ext. 3456

Mooresville Office
610 East Center Avenue (2nd Floor Govt. Center South)
Mooresville, NC 28115-2548
Phone: (704)660-3625

IREDELL COUNTY · NC

IREDELL COUNTY
PO Box 788
349 North Center St.
Statesville, NC 28677

APPLICATION NUMBER
318874 Issue Date:

Permit Type: ZONING

Parcel Number	Street Address	Jurisdiction
4872279911.000	342 TROY MILL RD	IREDELL COUNTY

Owner Information	Applicant Information
Name: STEVENSON MICHELLE+GREGORY	Name: STEVENSON MICHELLE+GREGORY
Address: , Phone:	Address: , Phone: (704)273-6391

Use Requested	Zone Code
Single-Wide Mobile Home	RA

Lot Acreage	F Setback	B Setback	L Setback	R Setback	Watershed	Flood Zone
1.543	35	35	15	15	WSII-BOW Back Creek	NO

Remarks

singlewide

REQUIREMENTS FOR ALL SINGLEWIDE MOBILE HOMES Must meet requirement R10 of the LDC. Must remove the towing apparatus, if it cannot be removed, it shall be screened; Must have a continuous underpinning; Must have 36 square foot front porch constructed within 12 inches of the floor elevation; Must have approved steps at all other secondary entrances and exits; Must face front property line and be no less than 20 degrees from parallel to the front property line. Original home must be removed before Certificate of Occupancy can be approved.

The applicant certifies that there are no deed restrictions, contractual agreements or governmental regulations of any kind that interfere with or prohibit the use of the property or the use for which this permit is requested. The applicant further acknowledges that enforcement of deed restrictions, plat conditions and other contractual agreements will not be undertaken by Iredell County and is the sole responsibility of the affected parties.


Date: 06/16/2021

Signature of Owner/Contractor

Permit Number	318874

TOTAL FEES:	$77.25

ZONING DISCLAIMER



Property Address 342 TROY Mill

The applicant certifies that there are no deed restrictions, contractual agreements or governmental regulations of any kind that interfere with or prohibit the use of the property or the use for which this permit is requested. Applicant further acknowledges that the enforcement of deed restrictions, plat conditions, and other contractual agreements will not be undertaken by Iredell County and is the sole responsibility of the affected parties.

Michelle D Clarence

Applicant

10/10/21

Date

IREDELL COUNTY PLANNING & DEVELOPMENT
PO BOX 788, STATESVILLE NC 28687-0788
349 N. Center Street / Building Standards Center
(704) 878-3118 / FAX (704)928-2025

318874

Residential Zoning Permit Application

What are you building?(Please check) *No building or addition shall be used for commercial, business, or other non-residential use unless appropriate permits and approval are obtained from Iredell County for commercial use.

Stick built___ Modular___ Duplex___ Singlewide ✓ Doublewide___ Pier___ Addition___ Bedroom addition___

Accessory dwelling (ie: M-I-L Suite, guest house) ___ Accessory building (ie: garage, shed)___ Swimming pool___

Are there any other structures currently on the property such as dwellings, sheds, garages? (Please list type below)
Building

Is there a septic tank on the property? (Yes) No If residence how many bedrooms? 2 and stories? 1

Please describe project (Details, Purpose, or Use): Single Family Hom

Please list square footage of project (Pier, Addition, Accessory Dwelling, Accessory Building only): 924

Does the property have community water? Yes (No) If yes, please list who provides it: _____

Does the property have community sewer? Yes (No) If yes, please list who provides it: _____

Owner Information

Property Owner's Name Michelle Stevenson Phone # 704 273 6391

Owner's Current Address 363 Troy Mill Rd Hamptonville NC 27020

Property Information

Property Address 342 Troy Mill Rd Hamptonville NC 27020 Parcel # 4/8722 79911.000

Subdivision:_____ Lot:___ Zoning:___ Watershed: Y (N) Flood Plain: Y (N) Township:_____

Directions to property (from a MAIN ROAD) Hwy 901 - Eagle Mills - (R) Houstonville - (L) Troy Mill - 1 mile on Right

Application Information

Applicant's Name or Company Michelle Stevenson Applicant's Phone # 704 273 6391

Applicant's Address 363 Troy Mill Rd Hamptonville NC 27020

If Company, Representative's Name and Title_____

IN APPLYING FOR A ZONING PERMIT I CERTIFY THAT ALL INFORMATION ON THIS APPLICATION IS CORRECT AND THAT ALL WORK WILL COMPLY WITH IREDELL COUNTY ZONING REGULATIONS. THE IREDELL COUNTY PLANNING & DEVELOPMENT DEPARTMENT WILL BE NOTIFIED OF ANY CHANGES THAT ARE MADE TO THIS PROJECT. I AM AWARE THAT THIS IS AN APPLICATION ONLY - NOT A PERMIT - AND DOES NOT CONSTITUTE APPROVAL OF THIS PROJECT. HOWEVER, IF THIS PROJECT IS APPROVED, THIS SIGNATURE IS VALID FOR MY PERMIT.

SIGNATURE OF APPLICANT Michelle Stevenson DATE 6/14/21

1,543
Iredell
RA
WS-III-BCW
NO Flood

IREDELL COUNTY · NC

Cash Register Receipt

Iredell County

Receipt Number
R11475

DESCRIPTION	ACCOUNT	QTY	PAID
PermitTRAK			**$327.25**
AP-318874 Address: 342 TROY MILL RD APN: 4872279911.000			**$327.25**
EH EXISTING SYSTEMS			$250.00
EXISTING SYSTEM INSPECTION	10492751-447004	0	$250.00
ZONING			$77.25
TECH FEE ZONING	104563-460450	0	$2.25
ZONING PERMIT	104563-472223	0	$75.00
TOTAL FEES PAID BY RECEIPT:R11475			**$327.25**

Date Paid: Wednesday, June 16, 2021

Paid By: STEVENSON MICHELLE+GREGORY

Cashier: JMP

Pay Method: CREDIT CARD 426775