HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: IR-A-69
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DAVID PIGMAN OWNER: ✓ AGENT: PHONE: 539-5559
ADDRESS: P.O BOX 23 APPLICATION DATE: 4/21/95 DATE EVALUATED: 5/22/95
U.G, NC 28689 PROPOSED FACILITY: 4 BR SW MH
PROPERTY SIZE: 4 ACRES
LOCATION OF SITE: US 21 N, TL HOUSTONVILLE, TR DARE, TL TROY MILL, 1ST DRIVE ON (L)
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	L 4%	0-48	SiC	WSBK	I:I/Fi/SP	1942 WETNES CONDITION 5
			MICACEOUS			1943/ 1956 SAPROLITE 5
						1944 RESTRICTIVE HORIZON 5
						1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.27
2	L 2-4%	0-48	SiC	WSBK	I:I/Fi/SP	1942 WETNES CONDITION 5
			MICACEOUS			.1943/.1956 SAPROLITE 5
						1944 RESTRICTIVE HORIZON 5
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.27
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.27
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DAVID PIGMAN
COMMENTS:

DRAFT