IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

Bldr Zeb Pratt

OWNER OR CONTRACTOR Everett Ramseur DATE 26 Feb 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N thru Harmony to RR Highway on left. Turn left go to SR # 1952 on left. Go to end of road. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 acre


Character & Porosity of Soil red Clay

Percolation Rate 40 min

Topography level

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 562½ Linear Ft. 221'

Depth of Stone in Lines 10" plus

Water Supply: Individual (✓)

Public ( )

Installed by Robert Hale

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY William M. Howard DATE 26 Feb 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold