DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: [redacted]
COUNTY: IREDELL
4873326185 (PT)

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: TERRY RENEGAR [redacted] APPLICANT: SAME
ADDRESS: 145 ELEANOR LANE, HAMPTONVILLE APPLICATION DATE: 2-16-99 DATE EVALUATED: 2-26-99
PROPOSED FACILITY: 3BR S/W M/H PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3.00 ACRE
LOCATION OF SITE: I-40 S 21 N, TL HUNTING CREEK, ON (L) ACROSS DITCH PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 6%	0-36	SBK / C	FI / SEXP					PS 0.3
		36-48	SBK / SC	FR / SEXP					
2	SLIGHT N 6%	0-32	SBK / C	FI / SEXP					PS 0.3
		32-48	SBK / SC	FR / SEXP					
3	L 6%	0-36	SBK / C	FI / SEXP					PS 0.3
		36-48	SBK / SC	FR / SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	II	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: J.C. POTTER, TERRY RENEGAR