IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Pleasant Hill Baptist Church DATE 6 Mar 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21N thru Harmony - Past RR Hayesburg Store - Cross creek. 1st Church on left. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Church approx 60 members

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )
Auto. Dishwasher	Yes ( )	No ( )
Auto. Wash. Machine	Yes ( )	No ( )
Site Suitable	Yes ( )	No ( )

Lot Area _____


Character & Porosity of Soil Cecil Clay Loan

Percolation Rate slow

Topography Slope to rear of property

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System 7 by 21 N

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 150
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic tank 50' from well. Lay joint from tank to drain line under private road and drainage ditch. Mr. Marion Smith gave permission to put drain line on his property.

CERTIFICATE OF COMPLETION BY WM Howard DATE 6 Mar 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold