IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR New Hope Baptist Church Parsonage DATE 13 Dec 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 21 N thru Statesville - Go appx 1.8 miles after crossing Hunting Creek. Trailer on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 150' X 200'

Character & Porosity of Soil Cecil Clay
Percolation Rate None
Topography Gently Slope
Depth to Water Table 6'
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by JC Cain

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic Tank installed for trailer but with purpose of building home later. Trailer has been moved off lot. O.K. for permit. Installed and inspected

CERTIFICATE OF COMPLETION BY C. M. Tolbert DATE 13 Dec 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold