IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR New Hope Baptist Church Parsonage DATE 15 Jan 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 21 N Above Harmony - Approx 1.8 miles after crossing Hunting Creek - Trailer on Right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ~~Appx~~ 151'X201'


Character & Porosity of Soil Red Clay

Percolation Rate none

Topography Hole to west of dwelling - 8-12% Slope

Depth to Water Table ok

Rock or other impervious formations ok



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J.C. Cain

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic tank system installed for a mobile home at present time. Septic tank situated for a home in the future

CERTIFICATE OF COMPLETION BY Wm Howard DATE 15 Jan 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold