DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 16748
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DEBORAH B. HAMPTON OWNER: ✓ AGENT: PHONE: 539-4974 / 878-9792
ADDRESS: RT 1 BOX 600 APPLICATION DATE: 8/5/93 DATE EVALUATED: 8/5/93
HAMPTONVILLE, NC 27020 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 3.95 ACRES
LOCATION OF SITE: US 21 N TL BARNARD MILL ROAD, 3RD DRIVE ON (L) BACK OFF ROAD
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	L 4-6	0-6	GR / SCL	1:1 / VFR	S	S	—	—	—
		6-38	WEAK SBK / C	1:1 / FR	S	S	PS	—	0.30
		38+	CLAY SAPROLITE	MIX	S	S	PS	PS	~~0.30~~
2	L 4-6	0-8	GR / SC	1:1 / VFR	S	S	+		—
		8-36	WSBK / C	1:1 / FR	S	S	PS	S	0.30
		36-48	WSBK / SC	MIX / FR	U 10YR7/2	S	U	S	—
3	L 4-6	0-6	GR / SCL	1:1 / VFR	S	S	—	—	—
		6-38	SBK / C	1:1 / FI	S	S	PS	—	0.30
		38+	CLAY SAPROLITE	MIX	S	S	—	PS	—
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.30 GPD/FT²
EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: JEFF HAMPTON
COMMENTS: