IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

04400

OWNER OR CONTRACTOR Kevin Wooten DATE 04-18-86 PERMIT NO.

PHONE: Business Home

LOCATION US 21N, Modular Home on Right just before Welch Mill Rd (SR 1828) S. R. No.

SUBDIVISION NAME LOT NO. SECTION OR BLOCK NO.


House ( ) Mobile Home (✓) Business ( ) Other Double wide / Modular

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Suitable
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	0.5 gal/ft²/day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	parent material

Lot Area Acreage

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed:

IMPROVEMENTS PERMIT BY Glenn Fox, Jr

COMMENTS:

CERTIFICATE OF COMPLETION BY Jerry L Pierce DATE 04-18-86

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold