IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR S.G. Miller DATE Aug. 19, 1977 PERMIT NO. _____

PHONE: Business _____ Home 468-2666

LOCATION 21 N through Houstonville ~ ½ mi. on left before county line S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 7 Ac.

Character & Porosity of Soil Cecil clay loam
Percolation Rate —
Topography Rolling
Depth to Water Table sink
Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"+
Water Supply: Individual (✓)
Public ( )

Installed by Jimmy Reavis

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: Owner decided not to use toilet in shop. Square footage is the same as drawn on the first improvements permit.

CERTIFICATE OF COMPLETION BY David R. Hinson DATE Aug 19, 1977

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold