44582

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15111

OWNER OR CONTRACTOR BESSIE CAMPBELL DATE 8/26/92 PERMIT NO. 12M-A-29

PHONE: Business _____ Home _____

LOCATION US 21 N, TR NC 901 E, MH ON (L) ~ 1 1/2 MILE S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☑ S/W Business ☐ Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area AMPLE

Soil Characteristics _____

Application Rate _____

Topography _____

Depth to Water Table EXISTING

Rock or other impervious formations _____

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank _____ Gals.

Nitrification Field:

No. of Lines _____

Sq. Ft. EXISTING Linear Ft. _____

Depth of Stone in Lines _____

Water Supply: Individual ☐ Public ☑

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS ① MH NOT ON SITE AT TIME OF INSPECTION, KEEP MH MINIMUM 5' FROM SYSTEM

② REPAIR AREA IS 100% CONVENTIONAL GRAVITY-FED

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY STEVE HEDRICK DATE 8/26/92

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold