IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 15726[illegible] PIN # 4886-62-7238 DATE

OWNER or APPLICANT Van Privette ~~PHONE: Business~~ 843-283-2437 Home: 843-448-8415

OWNER or APPLICANT ADDRESS 203 Skyview Lake RD Harmony NC 28634

LOCATION / DIRECTIONS 21 N (TR) 901 (L) Skyview Lake

SUBDIVISION BLOCK / SECTION LOT # LOT AREA .5 DESIGN FLOW 240 L.T.A.R. Exist

Septic Tank Exist Gallons: STB Exist Date Exist

Pump Tank Exist Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields No Lines 4 Linear Feet 300

Trench Width 36 Max. Trench Bottom Depth 36 Gravel Depth N4

☑ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: Pump to washer Box

Repair System Description: 50%

Maintenance Agreement Required ☐ YES ☐ NO

☐ GRAVITY ☑ PRESSURE

☐ Residence No. Bedrooms 2

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☑ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☑ Public ☐ Community

Comments / Conditions

At time of Inspection NO problems

Comments / Conditions

2 Bedroom Home Only

INITIAL SITE SKETCH

Put New alarm in New m/H for septic System and test → unsure alarm is working - Call Health department to insure it is working -

Alarm and pump must be on (2) Separate breakers and labeled

Skyview Lake RD

AS BUILT SKETCH

Drive

Pump

Alarm

Pump

Wash Box

Back fill for Positive drainage

Footer less than 2½ foot deep

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☑ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☑ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: X Van A Privette Date

Improvement Permit by: Date

Authorization to Construct by: Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by:

Operation Permit by: Date:

Existing System Inspected by: Date: 6-29-09

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant