IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Craysale DATE 1/18/24 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Harmony - 901 E - Turn LEFT on Rd. #2126. Trailer on LEFT BEFORE Bethel Church S. R. No. 2126


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1½ Acres

Character & Porosity of Soil Red Clay
Percolation Rate ~~none~~
Topography Level
Depth to Water Table ~~none~~
Rock or other impervious formations ~~none soft rock~~



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 362½ Linear Ft. 225
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Long S.T. Service

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Taylor Jr. Mathew Causey DATE 1/18/24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold