DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: 4881 29 1802
COUNTY: RUTHERFORD

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: ELIZABETH ROMERO APPLICANT: SAME
ADDRESS: 167 LANDMARK DR, MOCKSVILLE APPLICATION DATE: 3-2-99 DATE EVALUATED: 3-16-99
PROPOSED FACILITY: 3BR S/W WH PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3.7 ACRES
LOCATION OF SITE: US 21 N, TR POWELL, TL KENNESAW, ON L (R) #558 PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	L 10%	0-8	GR / SCL	VFR / SEXP					PS 0.3
		8-30	SBK / C	FI / SEXP					
		30-48	WSBK / SAP. CL	FR / SEXP					
2	L 8%	0-8	GR / SCL	VFR / SEXP					PS 0.3
		8-36	SBK / CL	FR / SEXP					
		36-48	WSBK / SAP. CL	FR / SEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: DANIEL & ELIZABETH ROMERO