IREDELL COUNTY HEALTH DEPARTMENT

8603

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David C Morgan DATE 5/20/88 PERMIT NO.

PHONE: Business Home

LOCATION Morgan property lot 3 Keaveau Rd S. R. No.

SUBDIVISION NAME LOT NO. 3 SECTION OR BLOCK NO.

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 26987

Character & Porosity of Soil Clay loam


Percolation Rate 45

Topography 2 to 6%

Depth to Water Table 10+

Rock or other impervious formations none

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12

Water Supply: Individual ( )
Public (✓)

Installed by James Hathcock

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: —

IMPROVEMENTS PERMIT BY JC Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY David Adams & Jack Moore R.S. DATE 2-22-89

EXISTING SYSTEM CHECKED BY: DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold