IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Sawyer DATE 2 Mar 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 21 N thru Harmony - T.L. on Powell Bridge Rd. # 2120 Lt to Rd # 2124 on right Go .6 mi. Trailer on Lft S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Cecil Clay Loam
Percolation Rate none
Topography rolling hills
Depth to Water Table wet
Rock or other impervious formations wet

Lot Area acreage



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. C. Cain

IMPROVEMENTS PERMIT BY _____

COMMENTS: Dirt Dam installed to take out some of fall.

CERTIFICATE OF COMPLETION BY W. M. Steward DATE 2 Mar 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold