DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: REDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: STEVE GUNTER APPLICANT: SAME
ADDRESS: _____ APPLICATION DATE: 6-1-99 DATE EVALUATED: ?
PROPOSED FACILITY: 3BR D/W PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3 ACRES
LOCATION OF SITE: US 21 N, TR E HOUSTONVILLE PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☑ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	SLIGHT N 4%	0-6	WGR / SL	VFR / NEXP	S	S	S	S	0.25 GPD/FT²
		6-10	WMSBK / SCL	FR / NEXP					
		10-20	MMSBK / C	FI / NEXP	2.5Y 6/6 MOTTLES 10YR 5/6 MOTTLES	~~PP~~			
		20-32	MCSBK / CL	FR / NEXP					
		32-48	MMABK / SCL	FR / NEXP					
2	SLIGHT N 5%	0-6	WGR / SL	VFR / NEXP	S	S	S	S	0.25 GPD/FT²
		6-12	WMSBK / SCL	FR / NEXP					
		12-34	MMSBK / C	FI / NEXP	2.5Y 6/6 MOTTLES	~~PS~~			
		34-48	MMABK / CL	FR / NEXP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	PS
System Type(s)	~~CONV~~ II	III
Site LTAR	0.25	0.25

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HEDRICK
OTHER(S) PRESENT: STEVE GUNTER