DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH, ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

Sheet 1 of 2
PROPERTY ID #: 488257565
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM
(Complete all fields in full)

OWNER: Lee Renegar
APPLICATION DATE: 03/30/15
ADDRESS: 1635 E Houstonville Rd
DATE EVALUATED: 05/04/15
PROPOSED FACILITY: SFD
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: 6.372 ac
LOCATION OF SITE: 21 to E. Houstonville Rd
PROPERTY RECORDED: Yes
WATER SUPPLY: [X] Private [ ] Public [X] Well [ ] Spring [ ] Other N/A
EVALUATION METHOD: [X] Auger Boring [X] Pit [ ] Cut
TYPE OF WASTEWATER: [X] Sewage [ ] Industrial Process [ ] Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	NS 12%	0-6	Gr SCL	fr SE	PS	PS	Pit	27"	PS .3
		6-20	SBk C	fi SE					
		20-27	WSBk BC	fi/fr SE					
		27-48	Mass Sap(l)	fr N/A					
2	NS 10%	0-7	Gr SCL	fr SE	PS	PS	N/A	36"	PS .3
		7-30	SBk C	fi SE					
		30-36	WSBk BC	fi/fr SE					
		36+	Mass CR	vfi N/A					
3	NS 12%	0-6	Gr SCL	fr SE	PS	PS	Pit	28"	PS .3
		6-21	SBk C	fi SE					
		21-28	WSBk C	fi SE					
		28-48	Mass Sap(l)	fr SE					
P 4	NS 12%	0-6	Gr SCL	fr SE	PS	PS	PS	N/A	PS .3
		6-18	SBk C	fi SE					
		18-24	WSBk BC	fi/fr SE					
		24-60	Mass Sap(l)	fr SE					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	III
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: H. Snow
OTHER(S) PRESENT:

COMMENTS:

SOIL/SITE EVALUATION

(Continuation Sheet-Complete all field in full)

DEPARTMENT OF HEALTH AND HUMAN SERVICES
DIVISION OF PUBLIC HEALTH
ENVIRONMENTAL HEALTH SECTION
ON-SITE WATER PROTECTION BRANCH

PROPERTY ID #: 4882575635
DATE OF EVALUATION: 05/04/15
COUNTY: Iredell

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
P5	10% NS	0-12	Gr SCL	fr SE	PS	PS	N/A	N/A	PS .3
		12-32	SBlC C	fi SE					
		32-50	WSBlC BC	fi/v SE					
P6	10% NS	0-11	Gr SCL	fr SE	PS	PS	W/A	W/P	PS .3
		11-36	SBlC C	fi SE					
		36-56	WSBlC BC	fi/n SE					
P7	12% NS	0-8	Gr SCL	fr SE	PS	PS	PS	W/A	PS .3
		8-24	SBlC C	fi SE					
		24-32	WSBlC BC	fi/v SE					
		32-61	Mass Sap(1)	fr N/A					

COMMENTS:

LEGEND

use the following standard abbreviations

LANDSCAPE POSITION	GROUP	SOIL TEXTURE	CONVENTIONAL .1955 LTAR*	LPP .1957 LTAR*	MINERALOGY/ CONSISTENCE	STRUCTURE
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	SEXP (Slightly Expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)			EXP (Expansive)	M (Massive)
D (Drainage Way)						CR (Crumb)
DS (Debris Slump)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		GR (Granular)
FP (Flood Plain)		L (Loam)				SBK (Subangular Blocky)
FS (Foot Slope)						ABK (Angular Blocky)
H (Head Slope)	III	Si (Silt)	0.6 - 0.3	0.3 - 0.15		PL (Platy)
L (Linear Slope)		SiCL (Silty Clay Loam)				PR (Prismatic)
N (Nose Slope)		CL (Clay Loam)				
R (Ridge)		SCL (Sandy Clay Loam)			MOIST	WET
S (Shoulder Slope)		SiL (Silt Loam)				
T (Terrace)					VFR (Very Friable)	NS (Non-sticky)
	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	FR (Friable)	SS (Slightly Sticky)
		SiC (Silty Clay)			FI (Firm)	S (Sticky)
		C (Clay)			VFI (Very Firm v. Very Sticky)	VS (Very Sticky)
		O (Organic)	None	None	EFI (Extremely Firm)	NP (Non-plastic)
						SP (Slightly Plastic)
						P (Plastic)
						VP (Very Plastic)

*Adjust LTAR due to depth, consistence, structure, soil wetness, landscape, position, wastewater flow and quality.

NOTES

HORIZON DEPTH	In inches below natural soil surface
DEPTH OF FILL	In inches from land surface
RESTRICTIVE HORIZON	Thickness and depth from land surface
SAPROLITE	S(suitable) or U(unsuitable)
SOIL WETNESS	Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
CLASSIFICATION	S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)

Evaluation of saprolite shall be by pits.

Long-term Acceptance Rate (LTAR): gal/day/ft^2

Show profile locations and other site features (dimensions, reference or benchmark, and North).

