IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Garry Vestal DATE Sept. 23, 76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy. 21 N to Houstonville, TR on rd. #2115, go across creek to rd. # 2114 on right – go 1 mile – trailer on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil sandy clay loam
Percolation Rate none
Topography 2 – 6 % slope
Depth to Water Table none
Rock or other impervious formations none observed



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. W. Jones

IMPROVEMENTS PERMIT BY Mike Howard

COMMENTS: sloppy system – barely meets county requirements

CERTIFICATE OF COMPLETION BY Wade R. Byrd + Andrew E. Causey DATE Sept. 23, 76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold