IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Mike Anthony DATE Nov 2-78 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION 21 N. East Statesville - T R on SR 2102 then Yadkin County Line - 3/4 mile on left. S. R. No. 2102

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Adequate

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate _____
Topography 6 - 10% Slope
Depth to Water Table _____ inch
Rock or other impervious formations None noted



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )
From Fathom Lake
Installed by J. C. Cain

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steven Todd DATE 11/2/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold