DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET ___ OF ___

PROPERTY I.D.#: 17B-A-49
DATE: 6/14/95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: JOSHUA EBRIGHT
ADDRESS: 142 EBRIGHT LANE ADVANCE, NC 27006
OWNER / AGENT: PHONE: (910) 998-6469
APPLICATION DATE: 6/11/95 DATE EVALUATED 6/14/95
PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 1.47 ACRES
LOCATION OF SITE: CORNER SHEFFIELD ROAD & ROCK SPRINGS ROAD
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1)(1): TEXTURE	.1941 (1)(2): STRUCTURE	.1941 (1)(3): MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	N	0-26	C	SBK	1:1 / FI/SS			.1942 Wetness Cond. S
	4%	26-48	SC	WSBK	1:1 / FR/FI			.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3 GPD/FT²
2								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR
3								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR
								.1942 Wetness Cond.
								.1943 Depth/.1956 Sapr.
								.1944 Restrictive Hori.
								.1948 Profile Class.
								Profile LTAR

AVAILABLE SPACE (.1945): S OTHER FACTORS (.1946): NONE SITE CLASSIFICATION (.1948): PS

SYSTEM TYPE: CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S): 0.3 GPD/FT²

EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: JOSHUA EBRIGHT

COMMENTS:

0001165