SHEET 1 OF 1

DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: 17B-A-12
DATE: 1-16-96
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: KELLY SHAW
ADDRESS: 404 HAMLET RD
HARMONY, NC 28634

OWNER ✓ AGENT: PHONE: 546-7328/872-9524
APPLICATION DATE: 12/19/95 DATE EVALUATED 1/16/96
PROPOSED FACILITY: 2 BR S/W MH
PROPERTY SIZE: 25 AC

LOCATION OF SITE: US 21 N, TR POWELL TR HAMLET, TL ROCK SPRINGS TL OLD SCHOOL RD,
WATER SUPPLY: On-site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

AT EVAL ON (R)

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	L	SBK	VI/FI			.1942 Wetness Cond. S
	6%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
2	L	0-48	L	SBK	VI/FI			.1942 Wetness Cond. S
	6%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S (OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: KELLY SHAW HAMPTON

COMMENTS: