IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Bobby Knight DATE 9-26-79 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Jerusalem - 70 E. TL on SR 2126 - cross Hunting Creek TL on SR 2121 - Mobile Home behind 1st Brick House on Rt. S. R. No. 2121

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ Rev. Santana

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4 ft
Lot Area _____			Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Strunk Bros.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 9/26/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold