HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 17B-A-58 (PART)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: DEBRA & ROBERT BLANKSCHIP OWNER: ✓ AGENT: PHONE: 546-5410
ADDRESS: 617 ROCK SPRINGS CH APPLICATION DATE: 11/9/99 DATE EVALUATED: 11/9/99
HARMONY, NC 28634 PROPOSED FACILITY: 3BR DW MH
PROPERTY SIZE: 5 ACRES
LOCATION OF SITE: ROCK SPRINGS ROAD DIRECTLY ACROSS FROM TEEN CHALLENGE
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓ Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	SS N 5%	0-6	CL	GR	1:1 / VFR	.1942 WETNES CONDITION 5
		6-30	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE PS (MIX @ 42")
		30-42	MICACEOUS SiC	WSBK	1:1 / FI	.1944 RESTRICTIVE HORIZON S
		42-48	SiC/SAP	WSBK	1:1 / FR	.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33 GPD/FT²
2	L 5%	0-4	CL	GR	1:1 / VFR	.1942 WETNES CONDITION S
		4-28	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE PS (MIX @ 40")
		28-40	MICACEOUS SiC	WSBK	1:1 / FI	.1944 RESTRICTIVE HORIZON S
		40-48	SiC/SAP	WSBK	1:1 / FR	.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.33
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33
OTHER FACTORS (.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: MR. ROBERTSON (PAT?), KELLY SHEEKS
COMMENTS:

DRAFT