IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steve Renegar DATE 10/12/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 21 N., T.R on 2115 in Houstonville, go 3 mile to end + T.L. on 2105, go .3 mile + T.L. into dirt drive, off road ½-½ mile S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area acreage


Character & Porosity of Soil Red Sand Loam

Percolation Rate none

Topography slope to gran

Depth to Water Table ok

Rock or other impervious formations none Observed



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10

Water Supply: Individual (✓)

Public ( )

Installed by J. W. Jones

IMPROVEMENTS PERMIT BY _____

COMMENTS: Good system

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 10/12/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold