IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

12900

OWNER OR CONTRACTOR H. W. SHARPE, JR DATE 5/30/91 PERMIT NO. 170-A-15A

PHONE: Business _____ Home _____

LOCATION US 21 N, TR HOUSTONVILLE RD, TL SANDY SPRINGS ROAD, 2ND DRIVE ON (L) PAST SANDY SPRINGS BAPT. CH S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1


Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 44 AC.

Character & Porosity of Soil PS
Percolation Rate .46 MPI / ET2
Topography 4-16% #5
Depth to Water Table > 41
Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement

CRS 4/21/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"
Water Supply: Individual (✓) WELL
Public ( )

Installed by Tommy Nixon

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Steve Hedrick

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve Hedrick DATE 5/30/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold