CI

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135419 PIN# 4893-38-2474 DATE 5-30-06

OWNER OR APPLICANT MATHEW MOORE PHONE: Business 336-463-5586 Home

ADDRESS 134 ARBORHILL RD YADKINVILLE NC 27055

LOCATION 21 N @ Harmony @ Sandy Springs @ Arborhill 1st Drive on left

SUBDIVISION BLOCK / SECTION LOT LOT AREA 15.405 Ac SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. .3

Septic Tank: 1000 Gallons: STB 1017 Date 10-29-05

Pump Tank: Gallons: PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200' Linear Feet 400'

No Lines 4x100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth 12" ☒ Gravity ☐ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: 600 GAL CONV

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☐ House/Mod. Home ☒ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons 6 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments/Conditions: (1) INSTALL LINES ON CONTOURS (2) MAINTAIN SETBACKS (3) MAINTAIN SETBACKS FROM NEIGHBORS WELLS

Comments/Conditions: TOPSOIL FROM BORROW

INITIAL SITE SKETCH

NOT TO SCALE

AS BUILT SKETCH

ALTERED SYSTEM USED 600 GAL 4 LINES X 75' LONG 300'

721'

Arborhill Rd

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Mark O Zink A-1 Backhoe date 6-2-06 Installed by: A-1 BACKHOE

Improvement Permit by: date 5-30-06 Operation Permit by: date 6-2-06

Authorization to Construct by: date 5-30-06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK